# PARSHALL FLUME METER NOTES CONTRACTOR SHALL TEST FLUME TO VERIFY CORRECT FLOW READING TO THE PRECAST CONCRETE VAULT FRP ACCESS TOP, SHALL BE H-20 RATED LADDER

METER VAULT ACCESS HATCH	
CLEAR OPENING	SEE TABLE
NO. OF LEAVES	SEE TABLE
RATING	H-20
MOUNTING*	ANCHOR
SAFETY GRATING**	YES
SAFETY CHAIN***	YES
GASKET	ODOR TIGHT
DRAIN	NO
SPRING ASSIST	YES

### ACCESS HATCH NOTES:

CAST FLUME INTO BASE OF

VAULT PER MANUFACTURES

RECOMMENDATION

STUBS, AND SONIC BRACKET, SEE FLUME SIZING


**GPM** 

3-73

13-250

>250

- ACCESS HATCH OVER METER VAULT SHALL BE MOUNTED USING STAINLESS STEEL BOLTS AS SHOWN ON THIS PLAN.
- \*ACCESS HATCH SHALL HAVE REMOVABLE SAFETY GRATING COVER BELOW ACCESS HATCH LID.
- \*\*\* SAFETY CHAINS SHALL BE PROVIDED ON ACCESS HATCHES AS DETAILED FOR EACH HATCH ON THIS SHEET.
- \*\*\*\*ACCESS HATCH TO HAVE HASP FOR PADLOCK



**VAULT SIZE** 

H2 PRE-CAST #577 OR

EQUAL H2 PRE-CAST #577 OR

EQUAL

**HATCH (MIN)** 

48"x60"

48"x60"

**LEAF** 

2

2

**FLUME SIZING** 

PARSHALL FLUME SIZE

2" - NOT TO BE USED WITH DOMESTIC SEWAGE

3"

CONSULT WITH CITY OF WENATCHEE ENGINEERING STAFF

## METER VAULT STRUCTURAL PLAN

### LADDER NOTES:

EXTERIOR, 12" MAX. LIFTS,

1557) TYP.

COMPACTED TO 95% MAXIMUM DRY

DENSITY AS DETERMINED BY THE

PRECAST CONCRETE VAULT, FOR SIZE SEE FLUME SIZING TABLE.

6" MIN. THICK FOUNDATION MATERIAL

CLASS A CONFORMING TO WSDOT SS

9-03.17, COMPACT TO 95% OF THE

MODIFIED PROCTOR, TYP.

MODIFIED PROCTOR TEST (ASTM D

EACH SIDE, TYP.

- LADDERS SHALL BE FIBER REINFORCED PLASTIC (FRP)


- LADDER MUST MEET CONSTRUCTION REQUIREMENTS OF ANSI A14.3
  LADDER BRACKET SHALL BE SERIES 625 VINYL—ESTER.
  ALL BOLT ASSEMBLIES AND GRATING HOLD DOWNS SHALL BE SERIES 316 STAINLESS STEEL.

5"X2-1/4" GALV. STL. SLEEVE IN TOP WITH

REMOVABLE PLUG. SLEEVES SHALL HAVE 2"

MIN. CLEARANCE TO ALL EDGES, TYP

CONTRACTOR TO FIELD VERIFY ALL DIMENSION PRIOR TO FABRICATION.



PARSHALL FLUME METER PLAN

ATTACH CONFINED SPACE ENTRY SIGN TO

ABOVE

FLUME

TYPICALLY

BOTTOM OF HATCH

**∂** ➡ PVC @ 1% INSTALL FLUME AND SET STRUCTURE PVC @ 0.5% SLOPE GREATER THAN LEVEL, NOT TO EXCEED 1% IN ANY DIRECTION INLET PIPE, MIN. PARSHALL FLUME WITH END ADAPTERS, PIPE


TABLE FOR SIZE, PLASTI-FAB OR EQUAL

PARSHALL FLUME METER ELEVATION

METER VAULT STRUCTURAL ELEVATION

TOP OF CHANNEL

VAULT FLOOR



# A A

LADDER DETAIL FOR PARSHALL FLUME METER

DETAIL FLUME **STANDARD PARSHALL** 

> enatri Ò

> > S - 330PAGE

1 OF 1